

DECLARATION OF PERFORMANCE

Date of issue: 08.07.2015
Replaces: No --- - CPR --/--- - yyyy/# of: dd/mm/yyyy

No. 0761-CPR-14/0108-2015/7

1	Unique identification of the product-type: PROMASEAL®-A																																																	
2	Type and batch numbers: as given on the packaging of the product																																																	
3	Intended uses as given in the ETA-14/0108: 3.1 - PROMASEAL®-A is a fire stopping acrylic for linear gaps/joints with different backfilling materials in walls and floors. 3.2 - The product is intended for: - use at internal conditions with humidity < 85% RH, excluding temperatures below 0°C, without exposure to rain and UV (TR 024:2009, type Z2) - use at internal conditions with humidity ≥ 85%, excluding temperatures below 0°C, without exposure to rain and UV (TR 024:2009, type Z1); - use at temperatures below 0°C, but no exposure to rain or UV (TR 024:2009, type Y2); - use at temperatures below 0°C, with exposure to UV but no exposure to rain (TR 024:2009, type Y1);																																																	
4	Name and contact address of the manufacturer: <div style="text-align: center;"> Promat GmbH St.-Peter-Straße 25 4021 Linz Austria Plant :17 www.promat.at </div>																																																	
5	Authorised representative: not applicable.																																																	
6	System or systems of Assessment and Verification of Constancy of Performance (AVCP): see table under section 9.																																																	
7	The construction product is not covered by a harmonised standard (hEN).																																																	
8	The declaration of performance concerns a construction product for which a European Technical Assessment has been issued. <div style="text-align: center;"> The Österreichische Institut für Bautechnik (OIB, Austria) has issued an ETA for this product with no. ETA-14/0108 based on ETAG 026-1 and ETAG 026-3. Notified product certification body: No. 0761 (MPA Braunschweig) Certificate of Constancy of Performance 0761 - CPR - 0442 </div>																																																	
9	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 35%;">Essential characteristics</th> <th style="width: 15%;">AVCP systems</th> <th style="width: 30%;">Performance</th> <th style="width: 20%;">Harmonised technical specification</th> </tr> </thead> <tbody> <tr> <td colspan="4">BR1: Mechanical resistance and stability.</td> </tr> <tr> <td colspan="4">BR2: Safety in the case of fire:</td> </tr> <tr> <td>Reaction to fire:</td> <td style="text-align: center;">1</td> <td style="text-align: center;">E.</td> <td rowspan="2" style="text-align: center; vertical-align: middle;">ETA 14/0108</td> </tr> <tr> <td>Resistance to fire:</td> <td style="text-align: center;">1</td> <td>This characteristic depends on the tested assembly. A fire resistant construction, in which the product was used, has been tested and the performance class has been established in a classification document in accordance with the applicable part of EN 13501.</td> </tr> <tr> <td colspan="4">BR3: Hygiene, Health and the Environment:</td> </tr> <tr> <td>Air permeability:</td> <td style="text-align: center;">-</td> <td style="text-align: center;">NPD (No Performance Declared)</td> <td rowspan="3" style="text-align: center; vertical-align: middle;">ETA 14/0108</td> </tr> <tr> <td>Water impermeability:</td> <td style="text-align: center;">-</td> <td style="text-align: center;">NPD (No Performance Declared)</td> </tr> <tr> <td>Release of dangerous substances:</td> <td style="text-align: center;">-</td> <td style="text-align: center;">Declaration (filed with the Technical Approval Body)</td> </tr> <tr> <td colspan="4">BR4: Safety and accessibility in use:</td> </tr> <tr> <td>Mechanical resistance and stability:</td> <td></td> <td style="text-align: center;">NPD (No Performance Declared)</td> <td rowspan="3" style="text-align: center; vertical-align: middle;">ETA 14/0108</td> </tr> <tr> <td>Resistance to impact and movement:</td> <td style="text-align: center;">-</td> <td style="text-align: center;">NPD (No Performance Declared)</td> </tr> <tr> <td>Adhesion:</td> <td></td> <td style="text-align: center;">NPD (No Performance Declared)</td> </tr> </tbody> </table>			Essential characteristics	AVCP systems	Performance	Harmonised technical specification	BR1: Mechanical resistance and stability.				BR2: Safety in the case of fire:				Reaction to fire:	1	E.	ETA 14/0108	Resistance to fire:	1	This characteristic depends on the tested assembly. A fire resistant construction, in which the product was used, has been tested and the performance class has been established in a classification document in accordance with the applicable part of EN 13501.	BR3: Hygiene, Health and the Environment:				Air permeability:	-	NPD (No Performance Declared)	ETA 14/0108	Water impermeability:	-	NPD (No Performance Declared)	Release of dangerous substances:	-	Declaration (filed with the Technical Approval Body)	BR4: Safety and accessibility in use:				Mechanical resistance and stability:		NPD (No Performance Declared)	ETA 14/0108	Resistance to impact and movement:	-	NPD (No Performance Declared)	Adhesion:		NPD (No Performance Declared)
Essential characteristics	AVCP systems	Performance	Harmonised technical specification																																															
BR1: Mechanical resistance and stability.																																																		
BR2: Safety in the case of fire:																																																		
Reaction to fire:	1	E.	ETA 14/0108																																															
Resistance to fire:	1	This characteristic depends on the tested assembly. A fire resistant construction, in which the product was used, has been tested and the performance class has been established in a classification document in accordance with the applicable part of EN 13501.																																																
BR3: Hygiene, Health and the Environment:																																																		
Air permeability:	-	NPD (No Performance Declared)	ETA 14/0108																																															
Water impermeability:	-	NPD (No Performance Declared)																																																
Release of dangerous substances:	-	Declaration (filed with the Technical Approval Body)																																																
BR4: Safety and accessibility in use:																																																		
Mechanical resistance and stability:		NPD (No Performance Declared)	ETA 14/0108																																															
Resistance to impact and movement:	-	NPD (No Performance Declared)																																																
Adhesion:		NPD (No Performance Declared)																																																

BR5: Protection against noise:			
Airborne sound insulation:		NPD (No Performance Declared)	ETA 14/0108
BR6: Energy Economy and Heat Retention:			
Thermal conductivity:	-	NPD (No Performance Declared)	ETA 14/0108
Water vapour permeability (transmission coefficient):	-	NPD (No Performance Declared)	
Durability:			
Basic durability assessment:		In accordance with the declared use, class Z2, Z1, Y2, Y1 according EOTA TR024 and in conformity with ETAG 026-3.	ETA 14/0108

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

The reader of this document is invited to verify on the website www.promat-ce.eu the relevant version..

The Safety Data Sheet (SDS) 1907/2006/EG for PROMASEAL®-A is available on request.

Signed for and on behalf of the manufacturer by:

Name: Bettina Rothböck
 Function: Product Manager Fire Stopping & Intumescent Seals

Linz, 7/8/2015

Signature: